

# Rockland Drinking Water System

---

Waterworks # 210000639  
System Category – Large Municipal Residential

## Annual Water Report

Prepared For:  
The Corporation of the City of Clarence Rockland

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup> 2024

Issued: February 24, 2025

Revision: 0



This report has been prepared to satisfy the annual reporting requirements in O.Reg 170/03 Section 11 and Schedule 22

## Table of Contents

<b>Revision History.....</b>	<b>1</b>
<b>Report Availability.....</b>	<b>1</b>
<b>Compliance Report Card .....</b>	<b>1</b>
<b>System Process Description .....</b>	<b>1</b>
Raw Source .....	1
Treatment .....	2
Treatment Chemicals used during the reporting year: .....	2
Distribution .....	2
<b>Summary of Non-Compliance .....</b>	<b>2</b>
Adverse Water Quality Incidents.....	2
Non-Compliance .....	2
Non-Compliance Identified in a Ministry Inspection:.....	3
<b>Flows .....</b>	<b>3</b>
Raw Water Flows .....	3
Total Monthly Flows (m3/d).....	3
Treated Water Flows .....	4
Monthly Rated Flows .....	4
Annual Total Flow Comparison .....	5
<b>Regulatory Sample Results Summary.....</b>	<b>6</b>
Microbiological Testing.....	6
Operational Testing .....	6
Inorganic Parameters .....	6
Schedule 15 Sampling: .....	7
Organic Parameters .....	7
Additional Legislated Samples .....	9
<b>Major Maintenance Summary .....</b>	<b>9</b>
Water Treatment Plant Maintenance .....	9
Distribution System Maintenance .....	10
<b>Appendix A - WTRS Data and Submission Confirmation.....</b>	<b>A</b>

## Revision History

Date	Revision #	Revision Notes
February 24, 2025	0	Issued Annual Report

## Report Availability

This system serves more than 10,000 residents therefore the annual reports shall be made available publicly to residents of The Corporation of the City of Clarence-Rockland. Notification should be made available on the municipal website and copies provided free of charge if requested at the Municipal Office located at, 1560 Laurier St. Rockland On. K4K 1P7.

## Compliance Report Card

Compliance Event	# of Events
Ministry of Environment Inspections	Inspection - January 24, 2024 – Reported in 2023 Annual Report Inspection – January 28, 2025 – Report not received
Ministry of Labour Inspections	0
QEMS External Audit	1 Desktop Audit
AWQIs	0
Non-Compliance	0
Community Complaints	12
Watermain Breaks & Service Repairs	5

## System Process Description

### Raw Source

Raw water source for the Rockland Drinking Water System is the Ottawa River as per Permit to Take Water #3168-B2JK5N expiring on June 30<sup>th</sup> 2028. Raw water intake facility consists of a 630mm HDP# Series 45 pipe extending approximately 126 meters from the low lift pumping station into the Ottawa river. Water is conveyed to the water treatment facility by one of 3 vertical turbine pumps.

## Treatment

The Clarence Rockland Water Treatment Plant is a 13,500 m<sup>3</sup>/day conventional filtration type treatment plant with Actiflo® pre-treatment. The Plant is located at 125 Edwards Street in Rockland and services the City of Clarence Rockland and five Hamlets (Clarence Creek, St-Pascal Baylon, Hammond, Bourget and Cheney). The facility consists of the following components; Raw water intake obtained from the Ottawa River. A low lift pumping station including three vertical turbine pumps. Water is directed to two Actiflo® units followed by two rapid dual media gravity filters of sand and anthracite. Filtered water is disinfected and passed through a UV system consisting of two units. A baffled chlorine contact tank of 233.5 m<sup>3</sup> and two reservoirs having a total capacity of 471 m<sup>3</sup>. Secondary disinfection is achieved via chloramination at the discharge of the plant.

### Treatment Chemicals used during the reporting year:

Chemical Name	Use	Supplier
Sodium Hydroxide 50%	Pre and Post pH adjustment	Sodrox
Aluminium Chloride Sulphate (PAX-XL6)	Coagulant	Kemira
Polymer - Praestol DW27AG	Flocculation Agent	Northland chemicals
Sodium Hypochlorite	Post Disinfection	UBA
Ammonium Sulphate	Secondary Disinfection "Chloramination"	Brenntag

## Distribution

Water is pumped into the distribution system by four centrifugal high lift pumps. A Booster Station with three centrifugal pumps is used for the water demand of the Hamlets. The rate of water supplied is based on the three elevated water tower storage tanks and demand from the City of Clarence-Rockland and its Hamlets.

## Summary of Non-Compliance

### Adverse Water Quality Incidents

Date	AWQI #	Issue
No AWQI Issued for this year		

### Non-Compliance

Legislation	requirement(s) system failed to meet	Details	Corrective Action	Status
No Non-Compliance Issued for this year				

**Non-Compliance Identified in a Ministry Inspection:**

Legislation	requirement(s) system failed to meet	duration of the failure (i.e. date(s))	Corrective Action	Status
<p>Inspection - January 24, 2024 – Reported in 2023 Annual Report</p> <p>Inspection – January 28, 2025 – Report not received</p>				

**Flows**


The Rockland Drinking Water System is operating on average under half the rated capacity. During summer peak demands both actiflo units are required to work in order to meet demand and fire capacity levels in the water tower reservoirs.

**Raw Water Flows**

The Raw Water flows are regulated under the Permit to Take Water Ontario Regulation 387/04. Water Taking and Transfers requires all water takers to report daily water taking amounts to the Water Taking Reporting System (WTRS) electronic database. The 2024 Raw Flow Data was submitted to the Ministry electronically under permit PTTW #3168-B2JK5N. The confirmation and a copy of the data that was submitted are attached in Appendix A.


**Total Monthly Flows (m3/d)**

Max Allowable PTTW 14500 m3/d





**Monthly Rated Flows (L/s)**

Max allowable rate - PTTW 167.8 L/sec


**Treated Water Flows**

The Treated Water flows are regulated under the Municipal Drinking Water Licence Number: 175-101  
Issue Number: 5

**Monthly Rated Flows**Rated Capacity – MDWL WTP 13,500m<sup>3</sup>/day

Rated Capacity – MDWL Booster Pumping Station 3,975 m3/dayAnnual Total Flow Comparison

Please note that the booster station flows are included in the treated water WTP flows, and all flows are represented here as megalitres.

Total Annual ML

## Regulatory Sample Results Summary

### Microbiological Testing

	No. of Samples Collected	Range of E.Coli Results		Range of Total Coliform Results		Range of HPC Results	
		Min	Max	Min	Max	Min	Max
Raw Water	53	0	168	40	11200	N/A	N/A
Treated Water	53	0	0	0	0	2	6
Distribution Water	447	0	0	0	11	2	4

### Operational Testing

	No. of Samples Collected	Range of Results	
		Minimum	Maximum
Turbidity, In-House (NTU) - RW	157	2.5	34.5
Turbidity, On-Line (NTU) - TW	8760	0.16	0.29
Turbidity, On-Line (NTU) – Filter #1	8760	0.02	0.71
Turbidity, On-Line (NTU) – Filter #2	8760	0.01	0.62
Free Chlorine Residual, On-Line (mg/L) - TW	8760	1	2.31
Combined Chlorine Secondary Disinfection, On-Line (mg/L) – TW	8760	0.82	3.03
Combined Chlorine Residual, On-Line (mg/L) – DW	8760	0.91	2.3

NOTE: spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O.Reg 170/03

### Inorganic Parameters

These parameters are tested as a requirement under 170/03. Sodium and Fluoride are required to be tested every 5 years. Nitrate and Nitrite are tested quarterly and the metals are tested annually as required under 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O.Reg 169/03
- <MDL = Below the laboratory detection level

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Treated Water					
Antimony: Sb (ug/L) - TW	2024/07/16	<MDL 0.1	6.0	No	No
Arsenic: As (ug/L) - TW	2024/07/16	0.2	25.0	No	No
Barium: Ba (ug/L) - TW	2024/07/16	16.0	1000.0	No	No
Boron: B (ug/L) - TW	2024/07/16	8.0	5000.0	No	No
Cadmium: Cd (ug/L) - TW	2024/07/16	<MDL 0.015	5.0	No	No
Chromium: Cr (ug/L) - TW	2024/07/16	<MDL 1.0	50.0	No	No
Mercury: Hg (ug/L) - TW	2024/07/16	<MDL 0.02	1.0	No	No
Selenium: Se (ug/L) - TW	2024/07/16	<MDL 1.0	50.0	No	No



	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Uranium: U (ug/L) - TW	2024/07/16	<MDL 0.05	20.0	No	No
<b>Additional Inorganics</b>					
Fluoride (mg/L) - TW	2024/04/02	<MDL 0.1	1.5	No	No
Nitrite (mg/L) - TW	2024/01/22	<MDL 0.05	1.0	No	No
Nitrite (mg/L) - TW	2024/04/02	<MDL 0.05	1.0	No	No
Nitrite (mg/L) - TW	2024/07/02	<MDL 0.05	1.0	No	No
Nitrite (mg/L) - TW	2024/10/8	<MDL 0.05	1.0	No	No
Nitrate (mg/L) - TW	2024/01/22	0.23	10.0	No	No
Nitrate (mg/L) - TW	2024/04/02	0.25	10.0	No	No
Nitrate (mg/L) - TW	2024/07/02	0.31	10.0	No	No
Nitrate (mg/L) - TW	2024/10/8	0.16	10.0	No	No
Sodium: Na (mg/L) - TW	2024/04/02	10.9	20*	N/A	N/A

\*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified mg/L when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

#### Schedule 15 Sampling:

The Schedule 15 Sampling is required under O.Reg 170/03. This system is under reduced sampling. No plumbing samples were collected.

Distribution System	Number of Sampling Points	Number of Samples	Range of Results		MAC (ug/L)	Number of Exceedances
			Minimum	Maximum		
Alkalinity (mg/L)	4	8	25	41	N/A	N/A
pH	4	8	6.9	7.3	N/A	N/A
Lead (mg/L)	4	8	N/A	N/A	10	N/A

#### Organic Parameters

These parameters are tested annually as a requirement under O.Reg 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

TREATED WATER	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Alachlor (ug/L) - TW1	2024/07/16	< 0.3	5.0	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW1	2024/07/16	< 0.5	5.0	No	No
Azinphos-methyl (ug/L) – TW1	2024/07/16	< 1.0	20.0	No	No
Benzene (ug/L) - TW1	2024/07/16	< 0.5	1.0	No	No
Benzo(a)pyrene (ug/L) - TW1	2024/07/16	< 0.006	0.01	No	No
Bromoxynil (ug/L) - TW1	2024/07/16	< 0.5	5.0	No	No
Carbaryl (ug/L) - TW1	2024/07/16	< 3.0	90.0	No	No
Carbofuran (ug/L) - TW1	2024/07/16	< 1.0	90.0	No	No
Carbon Tetrachloride (ug/L) - TW1	2024/07/16	< 0.2	2.0	No	No
Chlorpyrifos (ug/L) - TW1	2024/07/16	< 0.5	90.0	No	No

TREATED WATER	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Diazinon (ug/L) - TW1	2024/07/16	< 1.0	20.0	No	No
Dicamba (ug/L) - TW1	2024/07/16	< 1.0	120.0	No	No
1,2-Dichlorobenzene (ug/L) - TW1	2024/07/16	< 0.5	200.0	No	No
1,4-Dichlorobenzene (ug/L) - TW1	2024/07/16	< 0.5	5.0	No	No
1,2-Dichloroethane (ug/L) - TW1	2024/07/16	< 0.5	5.0	No	No
1,1-Dichloroethylene (ug/L) - TW1	2024/07/16	< 0.5	14.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW1	2024/07/16	< 5.0	50.0	No	No
2,4-Dichlorophenol (ug/L) - TW1	2024/07/16	< 0.2	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW1	2024/07/16	< 1.0	100.0	No	No
Diclofop-methyl (ug/L) - TW1	2024/07/16	< 0.9	9.0	No	No
Dimethoate (ug/L) - TW1	2024/07/16	< 1.0	20.0	No	No
Diquat (ug/L) - TW1	2024/07/16	< 5.0	70.0	No	No
Diuron (ug/L) - TW1	2024/07/16	< 5.0	150.0	No	No
Glyphosate (ug/L) - TW1	2024/07/16	< 25.0	280.0	No	No
Malathion (ug/L) - TW1	2024/07/16	< 5.0	190.0	No	No
Metolachlor (ug/L) - TW1	2024/07/16	< 3.0	50.0	No	No
Metribuzin (ug/L) - TW1	2024/07/16	< 3.0	80.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW1	2024/07/16	< 0.5	80.0	No	No
Paraquat (ug/L) - TW1	2024/07/16	< 1.0	10.0	No	No
PCB (ug/L) - TW1	2024/07/16	< 0.05	3.0	No	No
Pentachlorophenol (ug/L) - TW1	2024/07/16	< 0.2	60.0	No	No
Phorate (ug/L) - TW1	2024/07/16	< 0.3	2.0	No	No
Picloram (ug/L) - TW1	2024/07/16	< 5.0	190.0	No	No
Prometryne (ug/L) - TW1	2024/07/16	< 0.1	1.0	No	No
Simazine (ug/L) - TW1	2024/07/16	< 0.5	10.0	No	No
Terbufos (ug/L) - TW1	2024/07/16	< 0.5	1.0	No	No
Tetrachloroethylene (ug/L) - TW1	2024/07/16	< 0.5	10.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW1	2024/07/16	< 0.2	100.0	No	No
Triallate (ug/L) - TW1	2024/07/16	< 10.0	230.0	No	No
Trichloroethylene (ug/L) - TW1	2024/07/16	< 0.5	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW1	2024/07/16	< 0.2	5.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L) - TW1	2024/07/16	< 10.0	100.0	No	No
Trifluralin (ug/L) - TW1	2024/07/16	< 0.5	45.0	No	No
Vinyl Chloride (ug/L) - TW1	2024/07/16	< 0.2	1.0	No	No

DISTRIBUTION WATER	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Trihalomethane: Total (ug/L) Annual Running Average - DW	2024	43.5	100.0	No	No
HAA Total (ug/L) Annual Running Average - DW	2024	29.7	80.0	No	No

MAC = Maximum Allowable Concentration as per O.Reg 169/03

BDL = Below the laboratory detection level

### Additional Legislated Samples

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or Municipal Drinking Water Licence	Parameter	Date Sampled	Result	Total Chlorine Residual	Unit of Measure
Municipal Drinking Water Licence #175-101	Suspended Solids	Jan 15, 2024	3	0.0	mg/L
		Feb 6, 2024	12	0.0	mg/L
		Mar 19, 2024	8	0.0	mg/L
		April 9, 2024	5	0.0	mg/L
		May 7, 2024	12	0.0	mg/L
		June 4, 2024	4	0.0	mg/L
		July 2, 2024	5	0.0	mg/L
		Aug 6, 2024	7	0.0	mg/L
		Sep 3, 2024	9	0.0	mg/L
		Oct 8, 2024	3	0.0	mg/L
		Nov 5, 2024	4	0.0	mg/L
		Dec 2, 2024	3	0.0	mg/L
Annual Average			6.25	-	mg/L

## Major Maintenance Summary

### Water Treatment Plant Maintenance


Date	Details
2024	Various small modifications to the PLCs throughout the 2024 reporting year
Jan 11	Changed overload on actiflo #2
Apr 9	Replacement of tank liners for sodium hypochlorite, coagulant, sodium hydroxide storage.
Apr 22	Cut trees beside clearwell for future expansion
May 5	Replacement of Cyclone Sand Recirculation Pump
May 23	Took Ammonia motor #112 to repair brushes - Ordered a new motor
May 23	Replacement of Cyclone Sand Recirculation Pump
June 13	Install security camera
July 3	Chlorine pump # 92 Repair
July 3	Change Poly piping
July 25	Back Wash Waste pump # 45 repaired
Aug 20	Chlorine system repairs to piping
September 26	Fix chlorine Pump #93
Oct 10	Clean low lift pump well



Date	Details
Nov 2	Lifted low lift pump #1 and sent for repair in Ottawa
Nov 12	Low lift pump #1 rebuild and reinstall
Dec 12	Replacement of Filter 1 Media
Dec 27	Upgrade Outpost 5

### Distribution System Maintenance

Date	Location Reference	Details
Jan 11	Rockland Distribution	Watermain break repair 194 A Edward St
Feb 1	Rockland Distribution	Watermain break repair 194 C Edward St
March 12	Rockland Distribution	Watermain break repair Patricia St
March 18	Rockland Distribution	Watermain break repair 844 St-Jean
May 9	Clarence Creek/St-Pascal	Flush distribution dead end hydrants in Clarence Creek and St-Pascal
May 10	Rockland Distribution	Flush distribution dead end hydrants in Rockland
July 23	Rockland Distribution	Watermain repair on Laurier/Outaouais
Oct 16	St-Pascal Distribution	St-Pascal fire hydrants system operation check list, flush and winterizing
Oct 24	Bourget Distribution	Bourget fire hydrants system operation check list, flushing and winterizing
Oct 28	Hammond Distribution	Hammond fire hydrants system operation check list, flushing and winterizing.
Oct 29	Cheney Distribution	Cheney fire hydrants system operation check list, flushing and winterizing
October 30	Bouvier Tower	Cleaned Bouvier Tower clogged drains
Nov 27	Rockland Distribution	fire hydrants system operation check list, flushing and winterizing

## Appendix A - WTRS Data and Submission Confirmation





Ministry of the Environment,  
Conservation and Parks

| [WT DATA](#) | [USER PROFILE](#) | [CONTACT US](#) | [HELP](#) | [HOME](#) | [LOGOUT](#) |

Location: [WTRS](#) / [WT DATA](#) / [Input WT Record](#)WTRS-WT-008

Water Taking Data submitted successfully.

**Confirmation:**


Thank you for submitting your water taking data online.

Permit Number: 3168-B2JK5N  
Permit Holder: THE CORPORATION OF THE CITY OF CLARENCE-ROCKLAND.  
Received on: Feb 5, 2025 1:39 PM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.

[Print Confirmation](#) [Return to Main Page](#)

VERONIQUE VANDERGOTEN | 2025/02/05  
version: v4.5.0.21 (build#: 22)  
Last modified: 2018/09/18

 This site maintained by  
the Government of Ontario

©2025 [Queen's Printer for Ontario](#)

# ROCKLAND DRINKING WATER SYSTEM / Raw Water

Annual Values and Summary							Units: cubic meter per day					
Station:							Daily Max: 9275.7 on December 08					
Day	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
1	6540.60	7054.00	7198.70	7336.10	7781.80	8464.00	7640.00	7615.10	6428.60	6830.80	7345.70	8197.70
2	6275.90	6729.80	7653.10	6698.70	7204.30	8222.00	8078.10	7542.10	6833.60	7140.50	8448.70	5967.60
3	5577.40	5796.30	8762.70	6699.10	7463.50	8221.70	6507.40	7401.40	7219.10	7079.70	7191.20	5305.40
4	6933.80	6826.60	7927.50	6903.60	7306.80	8949.70	8259.10	6446.50	7444.00	6627.70	6913.80	5644.60
5	6171.30	7949.20	7698.50	6626.70	8095.50	8906.40	7430.30	7094.30	7020.70	7160.80	7271.50	5587.50
6	6167.80	5660.70	8040.70	7226.40	7762.50	8573.50	7063.90	6979.40	6893.10	6686.40	7048.80	5474.90
7	7534.50	6911.20	8399.40	6768.30	7322.90	8392.70	6880.00	6984.80	7090.90	6755.50	6517.20	7943.30
8	6927.50	7623.10	8577.70	7680.00	6603.40	6975.90	7207.70	7607.70	6229.10	7277.20	6702.20	9275.70
9	6481.90	6783.50	7078.30	7057.20	7749.50	6031.00	7854.60	6492.60	7395.80	6101.70	6792.50	8505.60
10	5753.40	6874.80	6656.20	7440.90	7305.20	8027.30	6485.90	6520.00	7409.60	7221.90	7046.60	7125.20
11	5994.40	8014.00	8706.80	7050.10	7534.50	7601.00	6888.50	6697.60	6303.80	7063.10	7285.10	7163.80
12	6585.30	6835.80	7211.30	7165.70	7489.40	7601.30	7454.80	6662.70	7714.50	6735.50	6881.20	6676.40
13	6332.30	6866.50	7122.20	6828.30	7858.10	6935.40	7415.50	7244.50	7283.80	6726.20	7129.70	7619.70
14	6428.60	7322.80	8352.60	7705.30	7022.60	7128.60	7698.70	7354.30	7205.00	6496.90	6050.30	8115.70
15	6486.90	6616.30	7633.80	7381.90	7506.60	7332.40	8040.30	7208.80	7786.50	7319.50	7414.40	7066.20
16	6598.70	7283.80	7622.60	6655.30	7344.10	6593.00	7165.20	7250.20	7317.10	6910.90	5916.00	7905.00
17	6753.70	6266.30	7003.50	7469.90	8234.60	8363.50	7176.10	6818.90	5729.60	6330.10	8163.20	8069.90
18	7058.10	7796.90	8416.00	6700.50	7371.20	7915.00	6985.10	7128.60	5918.60	4787.40	7181.30	7581.10
19	6523.00	6099.60	7106.50	7605.00	8514.30	8198.60	7092.20	6651.20	7582.70	5950.10	7050.90	7604.80
20	6485.00	6744.90	7068.40	5565.10	8430.90	8118.70	7829.30	7097.50	8171.60	8728.70	7086.10	7805.50
21	7103.10	7204.60	6972.20	7944.40	8481.60	8454.00	6757.60	6827.80	8662.70	6988.50	6902.90	7947.60
22	6923.60	6756.70	6575.00	8043.80	8806.70	7623.90	8343.00	7024.70	8734.20	7273.50	6181.50	8373.60
23	7302.40	6996.40	6444.50	7002.60	7687.40	7300.40	8378.80	6992.70	7744.00	6942.00	7738.40	7623.20
24	5852.60	7221.80	7248.60	5884.90	8364.10	7030.80	7709.10	7397.00	7033.30	6523.90	6914.40	7588.80
25	6840.50	7393.00	6662.90	8225.50	7533.80	7655.80	7204.70	7272.50	7683.70	6312.80	7414.90	7218.70
26	7291.60	7701.30	7264.20	7754.70	8401.90	6804.30	7377.80	6439.80	6735.40	6861.70	7084.70	7530.10
27	7134.90	6580.30	6681.10	6828.50	7583.20	7779.10	7303.10	7572.60	5691.40	6972.20	7144.50	7292.90
28	6728.20	7550.20	6754.90	7060.10	7073.40	7267.70	6801.20	7819.50	6953.10	7482.20	6574.60	7633.30
29	6930.50	7140.90	7390.40	7507.70	6856.30	7017.50	8162.40	6998.80	7585.40	6221.70	7352.00	7530.30
30	7393.40		6765.10	5327.30	6530.60	6512.80	7373.10	7208.60	7562.20	6102.40	7274.30	7136.50
31	6506.80		6608.30		6652.00		6858.50	6788.50		7028.10		8197.70
Min	5577.40	5660.70	6444.50	5327.30	6530.60	6031.00	6485.90	6439.80	5691.40	4787.40	5916.00	5305.40
Mean	6632.83	6986.25	7406.57	7071.45	7608.80	7666.60	7400.71	7069.05	7178.77	6794.83	7067.29	7377.69
Max	7534.50	8014.00	8762.70	8225.50	8806.70	8949.70	8378.80	7819.50	8734.20	8728.70	8448.70	9275.70